

**CALIDAD DEL GAS
 NOM-001-SECRE-2010**

Pto. de Calidad Naco

Junio

Día	Metano % VOL NORMA (84)	Etano % VOL NORMA (11)	N2 % VOL NORMA (4)	CO2 % VOL NORMA (3)	Total de Inertes % VOL NORMA (4)	Poder Calorifico MJoules /m3 NORMA (37,30 - 43,60)	Indice de Woobe MJoules /m3 NORMA (48,20 - 53,20)
	% C1	% C2	N2	CO2	CO2+N2	Poder Calorifico	I. Wobbe
6/1/2012	93.2041	3.8588	2.0337	0.3080	2.3417	38.3955	49.9011
6/2/2012	93.4210	3.7417	1.9917	0.3238	2.3155	38.3230	49.8674
6/3/2012	93.4769	3.6779	1.9945	0.3335	2.3280	38.2958	49.8437
6/4/2012	93.5044	3.6289	1.9931	0.3434	2.3365	38.2886	49.8334
6/5/2012	93.4613	3.6490	2.0077	0.3494	2.3571	38.2855	49.8210
6/6/2012	93.2476	3.9281	1.9992	0.3473	2.3464	38.3258	49.8501
6/7/2012	93.1278	4.0230	2.0131	0.3268	2.3399	38.3784	49.8881
6/8/2012	93.2445	3.9410	1.9221	0.3647	2.2868	38.3852	49.9069
6/9/2012	93.2686	3.9005	1.8784	0.3991	2.2775	38.3931	49.9074
6/10/2012	93.1823	3.9424	1.9193	0.3869	2.3062	38.4067	49.9053
6/11/2012	93.2118	3.8796	1.9077	0.3194	2.2271	38.5120	50.0165
6/12/2012	93.0978	3.9708	1.9481	0.3607	2.3087	38.4555	49.9382
6/13/2012	93.1049	3.9510	1.9695	0.3571	2.3266	38.4427	49.9244
6/14/2012	93.3708	3.7650	1.9539	0.4037	2.3576	38.3006	49.8170
6/15/2012	93.5101	3.6798	1.8039	0.4341	2.2380	38.3765	49.9069
6/16/2012	93.2545	3.8732	1.8323	0.4349	2.2672	38.4396	49.9302
6/17/2012	93.1557	3.9392	1.8763	0.4454	2.3217	38.4178	49.8910
6/18/2012	93.3365	3.7529	1.9582	0.4057	2.3639	38.3219	49.8259
6/19/2012	93.5100	3.5794	1.8925	0.4007	2.2933	38.3552	49.8775
6/20/2012	93.3245	3.7120	1.9788	0.4119	2.3907	38.3191	49.8107
6/21/2012	92.9986	3.9620	2.0310	0.3874	2.4183	38.4098	49.8567
6/22/2012	92.9215	4.0772	1.9920	0.3777	2.3698	38.4665	49.9134
6/23/2012	92.7562	4.2576	1.9449	0.3886	2.3335	38.5398	49.9695
6/24/2012	92.5266	4.4564	1.9359	0.3882	2.3241	38.6226	50.0216
6/25/2012	92.6016	4.3845	1.9883	0.3578	2.3461	38.5752	49.9916
6/26/2012	92.5762	4.4176	2.0078	0.3425	2.3503	38.5772	49.9944
6/27/2012	92.7584	4.2171	2.0921	0.3136	2.4057	38.4811	49.9209
6/28/2012	92.9773	4.0303	2.0404	0.3161	2.3565	38.4624	49.9311
6/29/2012	92.9280	4.0995	2.0206	0.3007	2.3214	38.5093	49.9775
6/30/2012	92.7172	4.2369	2.0362	0.3221	2.3583	38.5495	49.9793
Promedios	93.1259	3.9511	1.9654	0.3650	2.3305	38.4204	49.9073

* Datos en condiciones estándar: Temp. : 288,15° K , Presion: 101,325 KPa.

Zona: Resto del País

	% C1	% C2	N2	CO2	CO2+N2	Poder Calorifico MJ/m3	I. Wobbe MJ/m3
Máximo	93.5101	4.4564	2.0921	0.4454	2.4183	38.6226	50.0216
Mínimo	92.5266	3.5794	1.8039	0.3007	2.2271	38.2855	49.8107
Desv. Estándar	0.2927	0.2376	0.0652	0.0408	0.0434	0.0949	0.0605

**CALIDAD DEL GAS
 NOM-001-SECRE-2010**

Pto. de Calidad Fenosa

Junio

Día	Metano % VOL NORMA (84)	Etano % VOL NORMA (11)	N2 % VOL NORMA (4)	CO2 % VOL NORMA (3)	Total de Inertes % VOL NORMA (4)	Poder Calorífico MJoules /m3 NORMA (37,30 - 43,60)	Indice de Woobe MJoules /m3 NORMA (48,20 - 53,20)
	% C1	% C2	N2	CO2	CO2+N2	Poder Calorífico	I. Wobbe
6/1/2012	93.2041	3.8588	2.0337	0.3080	2.3417	38.3955	49.9011
6/2/2012	93.4210	3.7417	1.9917	0.3238	2.3155	38.3230	49.8674
6/3/2012	93.4769	3.6779	1.9945	0.3335	2.3280	38.2958	49.8437
6/4/2012	93.5044	3.6289	1.9931	0.3434	2.3365	38.2886	49.8334
6/5/2012	93.4613	3.6490	2.0077	0.3494	2.3571	38.2855	49.8210
6/6/2012	93.2476	3.9281	1.9992	0.3473	2.3464	38.3258	49.8501
6/7/2012	93.1278	4.0230	2.0131	0.3268	2.3399	38.3784	49.8881
6/8/2012	93.2445	3.9410	1.9221	0.3647	2.2868	38.3852	49.9069
6/9/2012	93.2686	3.9005	1.8784	0.3991	2.2775	38.3931	49.9074
6/10/2012	93.1823	3.9424	1.9193	0.3869	2.3062	38.4067	49.9053
6/11/2012	93.2118	3.8796	1.9077	0.3194	2.2271	38.5120	50.0165
6/12/2012	93.0978	3.9708	1.9481	0.3607	2.3087	38.4555	49.9382
6/13/2012	93.1049	3.9510	1.9695	0.3571	2.3266	38.4427	49.9244
6/14/2012	93.3708	3.7650	1.9539	0.4037	2.3576	38.3006	49.8170
6/15/2012	93.5101	3.6798	1.8039	0.4341	2.2380	38.3765	49.9069
6/16/2012	93.2545	3.8732	1.8323	0.4349	2.2672	38.4396	49.9302
6/17/2012	93.1557	3.9392	1.8763	0.4454	2.3217	38.4178	49.8910
6/18/2012	93.3365	3.7529	1.9582	0.4057	2.3639	38.3219	49.8259
6/19/2012	93.5100	3.5794	1.8925	0.4007	2.2933	38.3552	49.8775
6/20/2012	93.3245	3.7120	1.9788	0.4119	2.3907	38.3191	49.8107
6/21/2012	92.9986	3.9620	2.0310	0.3874	2.4183	38.4098	49.8567
6/22/2012	92.9215	4.0772	1.9920	0.3777	2.3698	38.4665	49.9134
6/23/2012	92.7562	4.2576	1.9449	0.3886	2.3335	38.5398	49.9695
6/24/2012	92.5266	4.4564	1.9359	0.3882	2.3241	38.6226	50.0216
6/25/2012	92.6016	4.3845	1.9883	0.3578	2.3461	38.5752	49.9916
6/26/2012	92.5762	4.4176	2.0078	0.3425	2.3503	38.5772	49.9944
6/27/2012	92.7584	4.2171	2.0921	0.3136	2.4057	38.4811	49.9209
6/28/2012	92.9773	4.0303	2.0404	0.3161	2.3565	38.4624	49.9311
6/29/2012	92.9280	4.0995	2.0206	0.3007	2.3214	38.5093	49.9775
6/30/2012	92.7172	4.2369	2.0362	0.3221	2.3583	38.5495	49.9793
Promedios	93.1259	3.9511	1.9654	0.3650	2.3305	38.4204	49.9073

* Datos en condiciones estándar: Temp. : 288,15° K , Presion: 101,325 KPa.

Zona: Resto del País

	% C1	% C2	N2	CO2	CO2+N2	Poder Calorífico	I. Wobbe
Máximo	93.5101	4.4564	2.0921	0.4454	2.4183	38.6226	50.0216
Mínimo	92.5266	3.5794	1.8039	0.3007	2.2271	38.2855	49.8107
Desv. Estándar	0.2927	0.2376	0.0652	0.0408	0.0434	0.0949	0.0605