

Reporte del Poder Calorífico del Gas Natural en el Punto de Medición de Energía Costa Azul de Gasoducto Rosarito S. de R.L. de C.V.			
9 de Abril de 2015			
Fecha	Hora	Poder calorífico superior mínimo (MJ/m3)	
4/9/2015	8:00:00	37.2468	
4/9/2015	9:00:00	37.2504	Mínimo NOM 001
4/9/2015	10:00:00	37.2562	37.5 MJ/m3 Poder Calorífico superior mínimo
4/9/2015	11:00:00	37.2576	
4/9/2015	12:00:00	37.2618	Limite te acuerdo a la tabla 1 del punto 5.1 de la NOM-001-SECRE-2010
4/9/2015	13:00:00	37.3232	
4/9/2015	14:00:00	37.3175	
4/9/2015	15:00:00	37.3080	
4/9/2015	16:00:00	37.2941	
4/9/2015	17:00:00	37.2732	
4/9/2015	18:00:00	37.2721	
4/9/2015	19:00:00	37.2555	
4/9/2015	20:00:00	37.2594	
4/9/2015	21:00:00	37.2549	
4/9/2015	22:00:00	37.2589	
4/9/2015	23:00:00	37.2727	
4/10/2015	0:00:00	37.2579	
4/10/2015	1:00:00	37.2595	
4/10/2015	2:00:00	37.2568	
4/10/2015	3:00:00	37.2563	
4/10/2015	4:00:00	37.2787	
4/10/2015	5:00:00	37.2545	
4/10/2015	6:00:00	37.2629	
4/10/2015	7:00:00	37.2847	
Promedio Diario		37.2697	Fuera de especificación
10 de Abril de 2015			
Fecha	Hora	Poder calorífico superior mínimo (MJ/m3)	
4/10/2015	8:00:00	37.2649	
4/10/2015	9:00:00	37.2498	
4/10/2015	10:00:00	37.2872	
4/10/2015	11:00:00	37.2623	
4/10/2015	12:00:00	37.2657	
4/10/2015	13:00:00	37.2723	
4/10/2015	14:00:00	37.2680	
4/10/2015	15:00:00	37.2847	
4/10/2015	16:00:00	37.2699	
4/10/2015	17:00:00	37.2668	
4/10/2015	18:00:00	37.2704	
4/10/2015	19:00:00	37.2690	
4/10/2015	20:00:00	37.2702	
4/10/2015	21:00:00	37.2694	
4/10/2015	22:00:00	37.2711	
4/10/2015	23:00:00	37.2826	
4/11/2015	0:00:00	37.2673	
4/11/2015	1:00:00	37.2969	
4/11/2015	2:00:00	37.2938	
4/11/2015	3:00:00	37.2573	
4/11/2015	4:00:00	37.2620	
4/11/2015	5:00:00	37.2637	
4/11/2015	6:00:00	37.2560	
4/11/2015	7:00:00	37.2558	
Promedio Diario		37.2699	Fuera de especificación
11 de Abril de 2015			
Fecha	Hora	Poder calorífico superior mínimo (MJ/m3)	
4/11/2015	8:00:00	37.2566	
4/11/2015	9:00:00	37.2567	
4/11/2015	10:00:00	37.2820	
4/11/2015	11:00:00	37.2660	
4/11/2015	12:00:00	37.2708	
4/11/2015	13:00:00	37.3214	
4/11/2015	14:00:00	37.2715	
4/11/2015	15:00:00	37.2695	
4/11/2015	16:00:00	37.2726	
4/11/2015	17:00:00	37.2691	
4/11/2015	18:00:00	37.2873	
4/11/2015	19:00:00	37.2891	
4/11/2015	20:00:00	37.2778	
4/11/2015	21:00:00	37.2830	
4/11/2015	22:00:00	37.2756	
4/11/2015	23:00:00	37.2908	
4/12/2015	0:00:00	37.2755	
4/12/2015	1:00:00	37.2777	
4/12/2015	2:00:00	37.2844	
4/12/2015	3:00:00	37.3655	
4/12/2015	4:00:00	37.2717	
4/12/2015	5:00:00	37.2726	
4/12/2015	6:00:00	37.2710	
4/12/2015	7:00:00	37.2991	
Promedio Diario		37.2815	Fuera de especificación
11 de Abril de 2015			
Fecha	Hora	Poder calorífico superior mínimo (MJ/m3)	
4/12/2015	8:00:00	37.2963	
4/12/2015	9:00:00	37.2724	
4/12/2015	10:00:00	37.2774	
4/12/2015	11:00:00	37.2859	
4/12/2015	12:00:00	37.2816	
4/12/2015	13:00:00	37.2833	
4/12/2015	14:00:00	37.2870	
4/12/2015	15:00:00	37.2936	
4/12/2015	16:00:00	37.3191	
4/12/2015	17:00:00	37.3301	
4/12/2015	18:00:00	37.2931	
4/12/2015	19:00:00	37.2862	
4/12/2015	20:00:00	37.2859	
4/12/2015	21:00:00	37.2929	
4/12/2015	22:00:00	37.2844	
4/12/2015	23:00:00	37.2791	
4/13/2015	0:00:00	37.2948	
4/13/2015	1:00:00	37.2984	
4/13/2015	2:00:00	37.2909	
4/13/2015	3:00:00	37.2827	
4/13/2015	4:00:00	37.2830	
4/13/2015	5:00:00	37.3182	
4/13/2015	6:00:00	37.2857	
4/13/2015	7:00:00	37.2903	
Promedio Diario		37.2913	Fuera de especificación