

## Anexo 1 - Registros de gas fuera de especificación H2S Promedio horario

| <b>Energía Mayakan S de RL de CV</b> |                                     |                   |                                     |
|--------------------------------------|-------------------------------------|-------------------|-------------------------------------|
| <b>enero-2015</b>                    | H2S Promedio hora                   | H2S Promedio hora | H2S Promedio hora                   |
|                                      | (ppm)                               | (ppm)             | (mg/m3)                             |
| <b>FECHA:</b><br><b>(dd/mm/aa)</b>   | <b>Mayakan</b><br><b>(No. 37.1)</b> | <b>Limite Max</b> | <b>Limite Max</b><br><b>NOM 001</b> |
| 01/01/2015 12:00                     | <b>4.83</b>                         | 4.4               | 6                                   |
| 03/01/2015 03:00                     | <b>6.02</b>                         | 4.4               | 6                                   |
| 03/01/2015 15:00                     | <b>4.61</b>                         | 4.4               | 6                                   |
| 03/01/2015 16:00                     | <b>4.74</b>                         | 4.4               | 6                                   |
| 03/01/2015 19:00                     | <b>4.88</b>                         | 4.4               | 6                                   |
| 03/01/2015 21:00                     | <b>5.90</b>                         | 4.4               | 6                                   |
| 04/01/2015 01:00                     | <b>4.54</b>                         | 4.4               | 6                                   |
| 04/01/2015 05:00                     | <b>8.67</b>                         | 4.4               | 6                                   |
| 05/01/2015 10:00                     | <b>6.92</b>                         | 4.4               | 6                                   |
| 05/01/2015 12:00                     | <b>5.85</b>                         | 4.4               | 6                                   |
| 05/01/2015 17:00                     | <b>6.83</b>                         | 4.4               | 6                                   |
| 06/01/2015 01:00                     | <b>4.88</b>                         | 4.4               | 6                                   |
| 06/01/2015 02:00                     | <b>5.21</b>                         | 4.4               | 6                                   |
| 06/01/2015 04:00                     | <b>8.55</b>                         | 4.4               | 6                                   |
| 06/01/2015 13:00                     | <b>8.38</b>                         | 4.4               | 6                                   |
| 06/01/2015 14:00                     | <b>5.46</b>                         | 4.4               | 6                                   |
| 06/01/2015 15:00                     | <b>6.67</b>                         | 4.4               | 6                                   |
| 06/01/2015 16:00                     | <b>5.70</b>                         | 4.4               | 6                                   |
| 06/01/2015 18:00                     | <b>6.75</b>                         | 4.4               | 6                                   |
| 06/01/2015 20:00                     | <b>4.86</b>                         | 4.4               | 6                                   |
| 11/01/2015 15:00                     | <b>4.52</b>                         | 4.4               | 6                                   |
| 12/01/2015 06:00                     | <b>8.43</b>                         | 4.4               | 6                                   |
| 13/01/2015 08:00                     | <b>4.52</b>                         | 4.4               | 6                                   |
| 13/01/2015 14:00                     | <b>5.33</b>                         | 4.4               | 6                                   |
| 14/01/2015 08:00                     | <b>4.75</b>                         | 4.4               | 6                                   |
| 21/01/2015 06:00                     | <b>5.54</b>                         | 4.4               | 6                                   |
| 21/01/2015 11:00                     | <b>7.31</b>                         | 4.4               | 6                                   |
| 21/01/2015 13:00                     | <b>4.67</b>                         | 4.4               | 6                                   |
| 21/01/2015 14:00                     | <b>6.53</b>                         | 4.4               | 6                                   |
| 22/01/2015 21:00                     | <b>5.55</b>                         | 4.4               | 6                                   |
| 24/01/2015 11:00                     | <b>4.78</b>                         | 4.4               | 6                                   |
| 24/01/2015 23:00                     | <b>4.86</b>                         | 4.4               | 6                                   |
| 25/01/2015 01:00                     | <b>5.26</b>                         | 4.4               | 6                                   |
| 25/01/2015 06:00                     | <b>4.50</b>                         | 4.4               | 6                                   |
| 25/01/2015 19:00                     | <b>5.92</b>                         | 4.4               | 6                                   |
| 26/01/2015 08:00                     | <b>5.08</b>                         | 4.4               | 6                                   |
| 27/01/2015 02:00                     | <b>6.57</b>                         | 4.4               | 6                                   |

### Anexo 1 - Registros de gas fuera de especificación H2S Promedio horario

|                  |             |     |   |
|------------------|-------------|-----|---|
| 28/01/2015 01:00 | <b>7.32</b> | 4.4 | 6 |
| 28/01/2015 06:00 | <b>4.99</b> | 4.4 | 6 |
| 28/01/2015 12:00 | <b>4.92</b> | 4.4 | 6 |
| 29/01/2015 06:00 | <b>4.92</b> | 4.4 | 6 |
| 30/01/2015 07:00 | <b>4.66</b> | 4.4 | 6 |
| 30/01/2015 08:00 | <b>4.72</b> | 4.4 | 6 |
| 31/01/2015 03:00 | <b>5.49</b> | 4.4 | 6 |